Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713025.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927039

SAMPLE LOCATION: FOUNTAIN 205 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017 TIME SAMPLED: 06:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	24.0	ug/l	15	7/17/17-09:55
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
		0		

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

* MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901 Telephone 908-688-8900

Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713024.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927041

SAMPLE LOCATION: LIBRARY FOUNTAIN - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-09:53
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713026.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927032

SAMPLE LOCATION: FOUNTAIN BY MAIN GYM - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.5	ug/l	15	7/17/17-09:58
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	- 		-	
	-			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370713027.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927048

SAMPLE LOCATION: SOCCER FIELD HOUSE FOUNTAIN - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.5	ug/l	15	7/17/17-10:01
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	Digested (Y/N) No			

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

immside, iven Jersey

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Harvey Klein, M.S., Laboratory Director

REPORT OF

ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713028.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927034

SAMPLE LOCATION: CAFETERIA KITCHEN - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:04
Analytical Method	EPA 200.9			
Reporting Limit, ug/I	1.0			
Dijution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey 07

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713029.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927042

SAMPLE LOCATION: FOUNTAIN 278 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017 TIME

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:07
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713030.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927043

SAMPLE LOCATION: FOUNTAIN 284 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:10
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			i	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713031.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927045

SAMPLE LOCATION: FOUNTAIN 180 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:07

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:12
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			
4=				

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713032.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927038

SAMPLE LOCATION: FOUNTAIN 201 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:15
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			
	+			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF

ANALYSIS

TO: Hackensack Board of Education 191 Second Street

DA

Toll Free Telephone Fax

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713033.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927040

SAMPLE LOCATION: FOUNTAIN 218 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:20

07601

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:18
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			_
Digested (Y/N)	No			
				
U				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue

Hillside, New Jersev 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713034.0

CLIENT # HAC08

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

DATE SUBMITTED: 7/13/2017

07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927028

SAMPLE LOCATION: FOUNTAIN 334 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:38
Analytical Method	EPA 200.9			-
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			-
				_

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnidep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet; www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713035.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927049

SAMPLE LOCATION: AUTO SHOP FOUNTAIN - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	6.7	ug/ī	15	7/17/17-10:41
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
€				
	i i			
			710	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

Hillside, New Jersey 07205

410 Hillside Avenue

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713036.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927029

SAMPLE LOCATION: FOUNTAIN 343 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017 TIME SAMPLED: 06:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	64.0	ug/l	15	7/17/17-10:46
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	_			
	-			
				_
				_
			-	

< = less than, not detected. Method-Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713037.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927033

SAMPLE LOCATION: FOUNTAIN OPPOSITE MAIN GYM - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-10:49
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			_
Dilution Factor	None			
Digested (Y/N)	No			
	-			
	-			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

CHIEF TO THE PARTY OF THE PARTY

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927027

SAMPLE LOCATION: FOUNTAIN 301 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.2	ug/l	15	7/17/17-10:52
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	<u> </u>			
	-	(i		

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com

Internet: www.gslabs.com

REPORT # 370713038.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927031

SAMPLE LOCATION: FOUNTAIN 307 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017 TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	3.0	ug/l	15	7/17/17-10:55
Analytical Method	EPA 200.9			
Reporting Limit, ug/l				
Reporting Littlit, ag/i	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				
	<u> </u>			
	1			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com

Internet: www.gslabs.com

REPORT # 370713039.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713040.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927026

SAMPLE LOCATION: FOUNTAIN 422 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:15

RESULT	UNITS	MCL	DATE ANALYZED
<1.0	ug/l	15	7/17/17-10:58
EPA 200 9			
NO			
		<1,0 ug/l EPA 200.9 1,0 None	<1,0 ug/l 15 EPA 200.9 1,0 None

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

CHE LE STREET

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713041.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927030

SAMPLE LOCATION: FOUNTAIN 406 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017 TIME SAMPLED: 06:15

IALYZE	DATE AN	MCL	UNITS	RESULT	ANALYSIS
7-11:00	7/17/1	15	ug/l	<1.0	Lead
	-			EPA 200.9	Analytical Method
				1.0	Reporting Limit, ug/l
				None	Dilution Factor
				No	Digested (Y/N)
	-				
	_			+	
				+	

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF

TO: Hackensack Board of Education 191 Second Street

NJ 07601

ANALYSIS

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927044

SAMPLE LOCATION: SINK IN 195 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.1	ug/l	15	7/17/17-11:09
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			i	
				1
-	- 			
				
	+			
	+			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Toli Free 800-273-8901

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713042.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue

Hillside, New Jersey 07205



REPORT # 370713043.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927046

SAMPLE LOCATION: FOUNTAIN 186 - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:07

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-11:12
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				
	-			
				
	 			
				-

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713044.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927035

SAMPLE LOCATION: CAFETERIA FOUNTAIN - HIGH SCHOOL

DATE SAMPLED: 7/13/2017 TIME SAMPLED: 06:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/ł	15	7/17/17-11:15
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	_			
	-			
	_			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927037

SAMPLE LOCATION: FOUNTAIN III - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-11:17
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
) X

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713045.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370713046.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927036

SAMPLE LOCATION: FITNESS CENTER FOUNTAIN - HIGH SCHOOL

DATE SAMPLED: 7/13/2017

TIME SAMPLED: 06:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-11:20
Analytical Method	EPA 200.9			
Reporting Limit, ug/I	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				
 	+ +			-
	+			

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersev 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713047.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927101

SAMPLE LOCATION: MAIN OFFICE FOUNTAIN - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.6	ug/l	15	7/17/17-11:23
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE PARTY OF THE P

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713048.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927103

SAMPLE LOCATION: FOUNTAIN BY BOYS' ROOM GYM - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.1	ug/l	15	7/17/17-11:26
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-
	+			
	+			
	1		· · · · · · · · · · · · · · · · · · ·	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370713049.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927107

SAMPLE LOCATION: FOUNTAIN OUTSIDE GYM WEST SIDE - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.6	ug/l	15	7/17/17-11:29
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
v				
The state of the s				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

07601

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713050.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack NJ

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927114

SAMPLE LOCATION: FOUNTAIN BY 202A - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017 TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-11:32
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			-	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

SHE WAS SHEET

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

TO: Hackensack Board of Education

REPORT OF ANALYSIS

NJ 07601

Hackensack ATT: Robert Blanchard

191 Second Street

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927111

SAMPLE LOCATION: FOUNTAIN OUTSIDE 242 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017 TIME SAMPLED: 07:13

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.5	ug/l	15	7/17/17-11:34
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Toll Free 800-273-8901 Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713051.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

THE PROPERTY OF THE PARTY OF TH

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713052.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927102

SAMPLE LOCATION: KITCHEN SINK - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.7	ug/Ī	15	7/17/17-11:54
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927105

SAMPLE LOCATION: ROOM 115 SINK - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	5.3	ug/l	15	7/17/17-11:57
	FD1.000.0			
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				_
				- 1
				_

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713053.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Hillside, New Jersey 07205

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713054.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927106

SAMPLE LOCATION: FOUNTAIN BY 219 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:09

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.6	ug/l	15	7/17/17-12:00
2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2				
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnidep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927104

SAMPLE LOCATION: FOUNTAIN BY 117 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-12:03
Analytical Method	EPA 200.9			
Generalise Lieste well				
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	1			
	+			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713055.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

minside, New Jersey

Toll Free 800-273-8901
Telephone 908-688-8960
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Harvey Klein, M.S., Laboratory Director

REPORT OF

TO: Hackensack Board of Education

REPORT # 370713056.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

191 Second Street

Mathew Klein, M.S., Founder (1916-1996)

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927109

SAMPLE LOCATION: FOUNTAIN BY 203 A - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:10

	UNITS	MCL	DATE ANALYZED
6.8	ug/l	15	7/17/17-12:05
EPA 200.9			
1.0			
None			
No			
 			
 			
			
	1.0 None	1.0 None	1.0 None

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713057.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

NJ 07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927108

SAMPLE LOCATION: FOUNTAIN BY 107 N - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-12:08
			-	
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-		-	
	-			
r				
	-			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

imiside, New Jersey



email: info@gslabs.com Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713058.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927023

SAMPLE LOCATION: FOUNTAIN OUTSIDE RM. 21 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017 TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-12:11
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	 			
His will be a second				
j				

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Telephone 908-688-8900

Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713059.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927018

SAMPLE LOCATION: FOUNTAIN OUTSIDE RM. 106 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:36

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.6	ug/ī	15	7/17/17-12:14
Analytical Method	EPA 200.9			_
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	- 			
	+			
	 			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713060.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927021

SAMPLE LOCATION: FOUNTAIN ACROSS RM. 3 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.2	ug/l	15	7/17/17-12:22
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				_
			ļ	
				_

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205



Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996). Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713061.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927017

SAMPLE LOCATION: FOUNTAIN OUTSIDE RM. 206 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:38

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	7.2	ug/l	15	7/17/17-12:25
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			*	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey 0'

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713062.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927113

SAMPLE LOCATION: FOUNTAIN OUTSIDE 310 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-12:28
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
		XIIII		
	-1			

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713063.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927150

SAMPLE LOCATION: FOUNTAIN BY 304 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.9	ug/l	15	7/17/17-12:31
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey 0

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713064.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927115

SAMPLE LOCATION: FOUNTAIN BY 215 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/i	15	7/17/17-12:34
				-
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-
			-	
	 			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

410 Hillside Avenue

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713065.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927110

SAMPLE LOCATION: FOUNTAIN BY 236 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017 TIME SAMPLED: 07:12

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	13.8	ug/l	15	7/17/17-12:37
Analytical Method	EPA 200.9			
Reporting Limit, ug/l				
	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713066.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927112

SAMPLE LOCATION: SINK IN 236 - MIDDLE SCHOOL

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	17.6	ug/l	15	7/17/17-12:39
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			_
Dilution Factor	None			
Digested (Y/N)	No			
	4			
				
NATIONAL PROPERTY OF THE PROPE				
			-	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713067.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927116

SAMPLE LOCATION: FOUNTAIN BY 134 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 07:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/17/17-12:42
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				
				_
	<u> </u>			
	+			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE RESTRICTION OF THE PERSON OF THE PERSON

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713068.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927022

SAMPLE LOCATION: FOUNTAIN CAF. 6 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	9.9	ug/l	15	7/17/17-12:45
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)				-
Digested (17N)	No			
			+	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713069.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927024

SAMPLE LOCATION: FOUNTAIN RM. 21 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.1	ug/l	15	7/17/17-12:48
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			
				_
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713070.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927025

SAMPLE LOCATION: FOUNTAIN RM. 10 A - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017 TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	9.8	ug/l	15	7/17/17-13:08
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
Digested (1714)	140			
				-
				
<u> </u>				

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713071.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927020

SAMPLE LOCATION: FOUNTAIN ACROSS RM. 3 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.1	ug/l	15	7/17/17-13:11
Analytical Method	EPA 200.9			
Reporting Limit, ug/i	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	+			
	-			
11				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713072.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927050

SAMPLE LOCATION: FOUNTAIN OUSIDE 313 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	3.3	ug/l	15	7/17/17-13:14
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
		-10		

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205



Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713073.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927016

SAMPLE LOCATION: FOUNTAIN IN RM. 118 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	20.2	ug/l	15	7/17/17-13:16
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet; www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713074.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927019

SAMPLE LOCATION: FOUNTAIN IN RM. 120 - MIDDLE SCHOOL, FAIRMONT

DATE SAMPLED: 7/11/2017

TIME SAMPLED: 06:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	111	ug/l	15	7/17/17-13:25
Analytical Method	EPA 200.9		ļ	
Analytical Method				
Reporting Limit, ug/l	1.0			
Dilution Factor	5			
Digested (Y/N)	No			
	_ 			

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnidep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

CHARLES STREET

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersev 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

191 Second Street

,

REPORT OF

TO: Hackensack Board of Education

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927118

SAMPLE LOCATION: KINDERGARDEN FOUNTAIN - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Ĺead	6.8	ug/l	15	7/17/17-13:28
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			

= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

31017

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713075.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director REPORT OF

ANALYSIS

TO: Hackensack Board of Education
191 Second Street

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927119

SAMPLE LOCATION: CAF. FOUNTAIN - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.3	ug/l	15	7/17/17-13:31
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
1				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713076.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

THE BOARD OF THE PARTY OF THE P

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713077.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927120

SAMPLE LOCATION: KITCHEN SINK - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.8	ug/ī	15	7/17/17-13:34
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-

<= less fhan, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713078.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

REPORT OF ANALYSIS

Hackensack

191 Second Street

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

TO: Hackensack Board of Education

SAMPLE ID: TAG #927130

SAMPLE LOCATION: SINK IN 202 - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	56.6	ug/l	15	7/17/17-15:26
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	2			
Digested (Y/N)	No			
				-
				Transport of the second
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL'= Maximum Contaminant Level allowed by State and Federal regulations.

THE BOOK CONTROL OF

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF

ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927140

SAMPLE LOCATION: SINK IN 417 - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	13.3	ug/l	15	7/17/17-15:28
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

Internet: www.gslabs.com

REPORT # 370713079.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966 email: info@gslabs.com

Garden S

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713080.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927134

SAMPLE LOCATION: FOUNTAIN BY 314 - PARKER

DATE SAMPLED: 7/12/2017 TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	5.5	ug/l	15	7/17/17-15:31
				
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	i i			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE REPORT OF THE PARTY OF THE

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927136

SAMPLE LOCATION: FOUNTAIN BY 418 - PARKER

DATE SAMPLED: 7/12/2017 TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.5	ug/l	15	7/17/17-15:34
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

Internet: www.gslabs.com

REPORT # 370713081.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966 email: info@gslabs.com

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey 07

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713082.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927135

SAMPLE LOCATION: FOUNTAIN BY 411 - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	9.7	ug/l	15	7/17/17-15:37
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-
				1

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

NOX STATE OF

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713083.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927117

SAMPLE LOCATION: FOUNTAIN BY CUSTODIAN ROOM - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.4	ug/l	15	7/17/17-15:40
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	_			
	1			
	1			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack
ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927138

SAMPLE LOCATION: FOUNTAIN BY 406 - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.7	ug/l	15	7/17/17-15:42
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	1		-	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900 Fax 908-688-8966

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713084.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

THE BOOK OF THE PARTY OF THE PA

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Harvey Klein, M.S., Laboratory Director

REPORT OF

ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713085.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927133

SAMPLE LOCATION: FOUNTAIN BY 317 - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.7	ug/l	15	7/17/17-15:45
			-	
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Illistato, Trem 0 23 c

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370713086.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927121

SAMPLE LOCATION: FOUNTAIN BY 201 - PARKER

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.1	ug/l	15	7/17/17-15:54
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-
				_
				_
				
				1

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE BOOK OF THE PARTY OF THE PA

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

DEPOST OF

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack

ATT: Robert Blanchard

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927132

SAMPLE LOCATION: FOUNTAIN BY 301 - PARKER

DATE SAMPLED: 7/12/2017 TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	3.1	ug/l	15	7/17/17-15:57
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				1
				<u> </u>

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713087.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713088.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927127

SAMPLE LOCATION: FOUNTAIN BY 303 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	27.6	ug/l	15	7/17/17-15:59
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			30	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnidep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Ćertified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713089.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

NJ

Hackensack

ATT: Robert Blanchard

07601

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927137

SAMPLE LOCATION: FOUNTAIN BY 205 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	24.9	ug/l	15	7/17/17-16:02
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	+			
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p> MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713090.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927139

SAMPLE LOCATION: FOUNTAIN BY 214 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.0	ug/l	15	7/17/17-16:05
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
4				
				-
				+

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901

Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713091.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927122

SAMPLE LOCATION: FOUNTAIN BY 113 - HILLERS

DATE SAMPLED: 7/12/2017 TIME SAMPLED: 06:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	55.2	ug/l	15	7/17/17-16:11
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor				
	2			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

nsack Board of Education

TO: Hackensack Board of Education 191 Second Street

Hackensack

NJ 07601

REPORT OF

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927129

SAMPLE LOCATION: FOUNTAIN BY AUDITORIUM - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06;30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.0	ug/l	15	7/17/17-16:13
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			115-77-115-	
2				
	-			
	-			
			-	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/eertnjdep.html</p>
MCL' = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900 Fax 908-688-8966

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713092.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

CHILL STATE OF THE STATE OF THE

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT # 370713093.0

CLIENT # HAC08

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

NJ

TO: Hackensack Board of Education 191 Second Street

DATE SUBMITTED: 7/13/2017

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927131

SAMPLE LOCATION: FOUNTAIN BY GYM - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06;45

07601

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.6	ug/l	15	7/17/17-16:16
	_			
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				-
	-			
				-

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713094.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927123

SAMPLE LOCATION: FOUNTAIN BY 336 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06;20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	5.8	ug/l	15	7/17/17-16:19
		· ·		
Analytical Method	EPA 200.9			
Analytical Method	1.0			-
Reporting Limit, ug/l				
Dilution Factor	None			
Digested (Y/N)	No			
				
				i
				_
				-

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue

Hillside, New Jersey 07205



Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713095.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927128

SAMPLE LOCATION: FOUNTAIN BY 401 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.6	ug/l	15	7/17/17-16:22
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com

Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713096.0 CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927143

SAMPLE LOCATION: FOUNTAIN BY 224 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	5.0	ug/l	15	7/17/17-16:42
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
				_
				1
			 	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com

Internet: www.gslabs.com

REPORT # 370713097.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927144

SAMPLE LOCATION: FOUNTAIN BY 413 - HILLERS

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:45

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	13.2	ug/l	15	7/17/17-16:45
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713098.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927142

SAMPLE LOCATION: FOUNTAIN 200 - JACKSON

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.3	ug/l	15	7/8/17-14:15
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

C.

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

amside, ivew bersey (

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713099.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927141

SAMPLE LOCATION: SINK 204 - JACKSON

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.3	ug/l	15	7/8/17-14:18
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	-			
	_			
-		·		

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927047

SAMPLE LOCATION: FOUNTAIN 305 - JACKSON

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:40

RESULT	UNITS	MCL	DATE ANALYZED
3.6	ug/l	15	7/8/17-14:20
EPA 200.9			
1.0			
No			
-			
-			
-			
	3.6 EPA 200.9 1.0 None	3.6 ug/l EPA 200.9 1.0 None	3.6 ug/l 15 EPA 200.9 1.0 None

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnidep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713100.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901 Telephone 908-688-8900

Fax 908-688-8966 email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS**

TO: Hackensack Board of Education 191 Second Street

REPORT # 370713101.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927147

SAMPLE LOCATION: FOUNTAIN OUTSIDE 209 - JACKSON

DATE SAMPLED: 7/12/2017 TIME SAMPLED: 07:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:23
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
-				
				
	-			
				_

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713102.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927145

SAMPLE LOCATION: CUSTODIAN ROOM SINK - JACKSON

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	7.2	ug/l	15	7/8/17-14:26
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None		1	
Digested (Y/N)	No			
	+			
	+			
			†	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue -Hillside, New Jersey 07205

Hillside, New Jersey 07

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713103.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927148

SAMPLE LOCATION: CAF. KITCHEN - JACKSON

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	8.2	ug/l	15	7/8/17-14:29
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	_			
				
				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE LEW SHAPE OF THE PARTY OF T

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713104.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

lackerisack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927149

SAMPLE LOCATION: FOUNTAIN OUTSIDE 106 - JACKSON

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:32
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	1			
				-
7				
				
	1			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

THE PARTY OF THE P

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713105.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927146

SAMPLE LOCATION: CAF. FOUNTAIN - JACKSON

DATE SAMPLED: 7/12/2017 TIME SAMPLED: 07:35

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.3	ug/l	15	7/8/17-14:35
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	_			
	_			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Garden

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713106.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927126

SAMPLE LOCATION: FOUNTAIN OUTSIDE 206 - ECDC

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	3.0	ug/l	15	7/8/17-14:43
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0	``		
Dilution Factor	None			
Digested (Y/N)	No			
				
				
				
	+			

<= less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713107.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927125

SAMPLE LOCATION: FOUNTAIN OUTSIDE 113 - ECDC

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:46
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
~~~				
	-			
	-			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Telephone 908-688-8900 Fax 908-688-8966

REPORT # 370713108.0

email: info@gslabs.com Internet: www.gslabs.com

REPORT OF **ANALYSIS** 

TO: Hackensack Board of Education 191 Second Street

CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: TAG #927124

SAMPLE LOCATION: KITCHEN SINK - ECDC

DATE SAMPLED: 7/12/2017

TIME SAMPLED: 06:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	28.2	ug/ī	15	7/8/17-14:49
Analytical Method	EPA 200.9			
Reporting Limit, ug/i	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
E				

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html MCL = Maximum Contaminant Level allowed by State and Federal regulations.

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713109.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: FIELD BLANK

SAMPLE LOCATION: FIELD BLANK FOR HACKENSACK BOE

DATE SAMPLED: 7/12/2017

TIME SAMPLED:

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:51
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0		<u> </u>	
Dilution Factor	None			
Digested (Y/N)	No			
- <del>-</del>				
		*		_

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

# THE REPORT OF THE PARTY OF THE

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director Hillside, New Jersey 072

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Hackensack Board of Education 191 Second Street REPORT # 370713110.0 CLIENT # HAC08 DATE SUBMITTED: 7/13/2017

Hackensack

NJ 07601

ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: FIELD BLANK

SAMPLE LOCATION: FIELD BLANK FOR HACKENSACK BOE

DATE SAMPLED: 7/12/2017

TIME SAMPLED:

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:54
Analytical Method	EPA 200.9			_
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
			ļ	

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs:com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

REPORT OF

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack
ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: FIELD BLANK

SAMPLE LOCATION: FIELD BLANK FOR HACKENSACK BOE

DATE SAMPLED: 7/12/2017

TIME SAMPLED:

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:57
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			
	<del></del>			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

31017

Telephone 908-688-8900

email: info@gslabs.com Internet: www.gslabs.com

REPORT # 370713111.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966



Bacteriological and Chemical Testing

410 Hillside Avenue Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director REPORT OF

**ANALYSIS** 

TO: Hackensack Board of Education 191 Second Street

NJ 07601

Hackensack ATT: Robert Blanchard

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: FIELD BLANK

SAMPLE LOCATION: FIELD BLANK FOR HACKENSACK BOE

DATE SAMPLED: 7/12/2017

TIME SAMPLED:

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	7/8/17-14:57
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			_
Digested (Y/N)	No			
(#				
				+

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html</p>
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

310171

Telephone 908-688-8900

email: info@gslabs.com

Internet: www.gslabs.com

REPORT # 370713112.0

CLIENT # HAC08

DATE SUBMITTED: 7/13/2017

Fax 908-688-8966